

AQUARIUS HIGH NECK SV

Brushed with PEX Hose

AT03-031

PRODUCT NUMBER

Fixing

Fixing length

The Aquarius range incorporate simple and modern design, with the latest electronic functionality:

Sensor-operated for maximum-hygiene and efficiency. 5-litres per-minute integrated flow-control.

Automatic purge function, Sensor range adjustment, Wave on/wave off function, Anti Vandal and Lock Out functions, Chlorination function.

Single mixed feed connection by PEX lined hose (15mm connection), External TMV required. Brushed finish.


Requires a Station kit to operate. Station kits available in Single Station Battery or Mains Single Station, 2 Station or 3 Station for multiple connections. Refer to Station kit Data sheets.

AT03-031	Brushed	Aquarius High Neck SV no touch tap
TECHNICAL DATA		
Type of tap		Aquarius High Neck SV
Material		Stainless Steel
Surface finish		Brushed
Gross weight		1.25 kg
Type of operation		No Touch Sensor
Type of mounting		Deck mounted
Type of mixing		Additional TMV may be required
Automatic purge		Yes* - Default: OFF
		Options: 3, 6, 12, 24, 36 & 48 hours
Purge run time		Default 1 min*
		Options: OFF, 30 secs, 1, 2, 4 & 8 mins
Spout projection / Spout height		130mm / 101mm
Minimum flow pressure		1.00 bar (Lower pressure station kits available)
Volume flow rate at 3 bar		5LPM (Other flow rates available)
Adjustable run time		Yes* - Default: 2 secs
		Options: 2, 5, 10, 15, 20, 30 secs For Academic Use Only.
Water connection		15mm PEX hose SolidWall&StadtedEditInition.
Anti-Vandal function		Yes For Academile Mile Only Only.
Lock out function		Default OFF*
		Options: OFF, 4, 6, 8 & 10 operations
Chlorination function		Yes* - Default 2 mins
		Options: 1, 2, 3, 4, 5, 10, 20 & 30 mins
Battery or mains statio	n kit	Single Battery: AT00-001
		Single Mains: AT00-002
		- Other options available. Contact DVS.
Working pressure		1-10 Bar (For Low / High pressure, Contact DVS.)
Max working temperati	ure	60°C For Academic V

3/4" BSP

Up to 50mm with flange nut





Last Updated: 2015-08-18, Dart Valley Systems





^{* (}Set By Handheld Programmer)