



C
E
R
T
I
F
I
C
A
T
E



Certificate number: 2310788 (2)

Issued 15/10/2024
Expires 25/10/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)
Model number(s) – see Appendix

KWC DVS.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009
Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

KWC DVS
Kemmings Close
Long Road
Paignton
Devon
TQ4 7TW
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2310788

The following products belong to this certificate

PRODUCT DESCRIPTION Range of infrared operated WC flush valves with plastic bodies and a control box. ATS3 – Without Production Surveillance.
MODEL(S) WCO1 To be installed using the following kit: WCO3 (flush valve kit)
SIZE: 1 1/2" BSP(M), size added October 2024 - 2" BSP (M).
SCOPE: Manufacturer recommended maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials not assessed.
MARKING DVS on sensor rosette.
MATERIALS Non-metallic materials not assessed. (BS6920)
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. Suitable for use in a WC suite, provided it forms an arrangement which meets the requirements of Type AUK1 and an appropriate WC performance specification. Please refer to the clarification of the requirements of the Water Supply (Water Fittings) Regulations, Byelaws in Scotland, as they apply to Type AUK1 air gaps in WC suites. When used in a close coupled/low level WC suite, to form part of a Type AUK1 air gap arrangement, the distance between the invert of the overflow and the spillover level of the WC pan must be no less than 300 mm.

Extra Notes