

CENTRAL MICROBIOLOGY & N. IRELAND PUBLIC HEALTH LABORATORIES

Belfast Health and Social Care Trust

Belfast City Hospital

Lisburn Road, Belfast, BT9 7AD

Telephone: (028) 9504 7871 Fax: (028) 90637773

Email: DL-BLL-NIPHL@belfasttrust.hscni.net

Customer: Sean Gibson

Address: Estate Services

Altnagelvin Area Hospital

Glenshane Road

Derry

Your Reference: 084571

Laboratory Reference: CML-15-00750

Sample Taken: 23/1/15 9:51

Sample Received: 23/1/15 14:10

Date Started: 23/01/15

Order Number:

Sample Description

Receipt Temperature [°C]:

Reason for test

Sampling point:

Place of sampling:

Sample description:

Other information:

Routine Sample

Shower-Hot Pre

Altnagelvin Hospital-Ward 46

Room H Ensuite-7401168

Quantity:


Survey code:

Analytical Results

Test	SOP Ref.	Result	Units
Pseudomonas aeruginosa	WM006	Not detected	cfu / 100mL

Report comment: No comment

Authorised By:



Kieran McCorry
Senior Biomedical Scientist

A UKAS accredited testing laboratory, No. 2017.

Tests marked * are not UKAS accredited. Those marked # may be outside guidance levels.
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.