Directory Search Results

WRAS Approval Number: 2004324

Approved Product

Range of basin pillar taps (chromium plated brass), incorporating ¼ turn ceramic disc headworks with single lever operating members. The spout outlets incorporate a plastic flow straightener. The products are supplied with metal or plastic back nuts (depending on model). Maximum working pressure 10.0 bar. Maximum operating temperature 60°C.

• Section: 1800 Taps (?section=1800)

• Section Subtitle: Pillar, metal.

• WRAS Approval Number: 2004324

• Expiry date: 30/04/2025

• **Size**: ½" BSP (M)

• Marking: DTC 34 (brand of Methven) on rear of body

• Installation Requirements R001 (/approvals/resources/fittings/installation_requirements/irn_r001)R005 (/approvals/resources/fittings/installation_requirements/irn_r005)

Model

CNTL01 (plastic backnuts),

EXG5051 (plastic backnuts),

DLT101 (plastic backnuts),

DLT SPEC101 (brass backnuts),

208.0574.186 (plastic backnuts),

DLV101 (plastic backnuts),

KEE DLT101 (brass backnuts),

KEE DLT101-4 (plastic backnuts),

VW DLT101 (brass backnuts),

DLT SPEC101PC (brass backnuts) &

SF2401CP (brass backnuts).

• Factor: Methven UK Ltd View All Listings by this Company (?company=16309)