

Declaration of Performance

We

KWC DVS LTD
of
Kemmings Close, Long Road, Paignton, Devon

Hereby declare that:

Equipment: **WC Air Break**

Model Number: **WC00-098**

Has been tested with the following components:

WC03-043 - WC Direct Flushing Kit 6v

VR07-020 - Multi-Washroom Control

AC17-015 - 28mm Orifice 6v Solenoid Valve (swapped to 12v via AC17-011 when used with washroom control box)

AC17-011 - 12v 3W Solenoid Coil

WC02-031 - 430 x430 Standard 38mm Flushpipe

VR01-010 - High Security WC Pan

And has achieved **good washdown with no splashback from the Air Break vents** at the following dynamic pressures and solenoid voltages:

Voltage	Dynamic Pressure (bar)	Flush time (seconds)
6v, 12v	1.5	6
6v, 12v	2.0	6
6v	2.5	6
6v	3.0	6

I hereby declare the equipment named above has achieved adequate performance under the listed conditions.

Signed:



Name: Scott Crok

Position: Director

Place of Issue: Paignton

On: 24th October 2025